

# 9460 and 9460-A Horizontal Mounting Instructions

The 9460 and 9460-A are set up to be installed standing on the rubber feet. Installing in this position insures that the Air Pressure Sensing Switch is in the correct position. The switch must be perpendicular to the ground. Otherwise, gravity will effect it and it may malfunction.

The switch is mounted on the fan with 2 hex nuts on 2 long screws. To mount horizontally and keep the switch in the correct position it is necessary to remove the hex nuts that hold the switch in place and re-mount the switch on a wall, joist or a roughed in board. **DO NOT detach the wiring!** Just move the switch. There is plenty of slack in the wire to do this. For a 9460-A, do this for each switch.

## **ACME MIAMI**

1290 NW 74 St Miami, FL

800-654-2154